

Sundries Elevator

Hoistway Structure






Concrete Brick & Concrete Other

Unstandard Standard

NOTE

Technical Requirement:

HW	HOISTWAY WIDTH	CW	CAR INSIDE WIDTH	Type	TZJ 200 / 0.4 - VF		
HD	HOISTWAY DEPTH	CD	CAR INSIDE DEPTH	F/P/D	/	/	Door type Straight door
OP	DOOR OPENING WIDTH	CH	CAR HEIGHT	load	200	kg	speed 0.4 m/s
ROP	WALL OPENING WIDTH	MRW	MACHINE ROOM WIDTH	Machine			Roping 1:1
OPH	DOOR OPENING HEIGHT	MRD	MACHINE ROOM DEPTH	T/sheave	∅		D/sheave ∅
OH	OVERHEAD HEIGHT	MRH	MACHINE ROOM HEIGHT	car sheave	∅		CW sheave ∅
CAR DBG	DISTANCE BETWEEN CAR GUIDE RAILS			Shaft	HW 1500	mm x HD 1150	mm
CWT DBG	DISTANCE BETWEEN COUNTERWEIGHT GUIDE RAILS			Cabin	CW 950	mm x CD 930	mm
				Door	OP 950	mm x OPH 1200	mm



OH	≥3800
Rise	H
5 F	
4 F	
3 F	
2 F	
1 F	
G F	
B F	
Pit	≥750
Floor	Height

Support Force (N)							
R1	R2	R3	R4	P1	P2	P3	P4
1000	1000			2500	2000		

Technical Requirement

1. Power supply: machine room need equiped with power supply. Power supply box need be locked. Power supply should be 3P.5 wires, 380V 50Hz. Voltage tolerance ±7%, input power more than 50% of motor power, also equiped with air switch same capacity with power supply, also allow the supplement leakage protector. When use VVVF, need use special leakage switch. Ground resistor should be < 4Ω. It should use insulated conductor from floor to machine room. Keep separate for null wire and ground wire.

2. Shaft requirement, it should be only for lift, can not install non-related device (pipe, cable, etc), and should keep the person entrance into. The shaft plan size mean the min size measured by plumb line, tolerance ±50mm. Basically not allow the protruding beam and column. The proof pressure of shaft side should be ≥ 24MPa. Recommend to use full concrete, can not use the reserved steel. In case use solid brick, it should use reserved steel or make the ring beam on the surface of reserved steel, height ≥ 300mm. If use hollow brick, can choose C25 concrete fill into the wall, also make the ring beam on the surface of reserved steel, height ≥ 300mm. If the shaft front wall is brick construction, it should make the concrete beam upsid of door hole to fix the landing door bracket, height ≥ 300mm. If have the requirement in the drawing, it should make the concrete in the entrance of hall door. It should equiped with lamp, brightness ≥ 50LX, install the lamp at 0.5m from the top and the bottom, in the middle each lamp, at ≤ 1m. The buffer block should be made accompany with special person. Before that need make the reserved 240x240 joint bar, height ≥ 500mm from the pit floor, and should water proof. Keep the space for person entrance. Pit ladder is by user. Should installed it in a suitable place. If there have basement downside of the pit should make the buffer block extend to the solid floor downside. If the floor distance between 2 floor > 1m, should set the safe door with the width 350mm, height 1800mm.

3. Machine room requirement (not for MRL). It had the passageway for the traction machine. keep the entrance unblocked. the door opens outward, also can be locked. Installed the fan, keep the humidity < 85%, temperature +5℃-40℃, surrounding the reserved hole should make the 50mm hole, keep the floor plan, also bear the load 700kg/m². The motor beam should be supported in the concrete block, this concrete block should extend to the building beam or bearing wall. Bearing side should make the reserved same side steel, thickness 2mm, bearing side thickness should over the wall thickness 20mm, total thickness more than 75mm. Standard wall 200mm, recommed the bearing wall thickness ≥ 200mm. The hook in the machine room should indicate the max. load. It should install the ladder and barrier in case have stair.

Overhaul door height ≥ 1400

By others

The hook (Skn indicate on the hook)

Overhaul door height ≥ 1400

800

≥ 1000

250

OPH ≥ 3800

800

Rise = H

Floor height ≥ 2800

≤ 1500

700

Pit ≥ 750

CAR & CWT RAIL BRACKET SPACING ≤ 2000

Drawing		approver	
Drawing No.	TZJ 200 - 02 -		
manufacturing no.			
Project name			
FUJI PRECISION			