



210002349425



(2020)国认监认字(134)号



中国认可
国际互认
检测
TESTING
CNAS L0454

Type Test Certificate for Special Equipment (Lift)

Certificate No. TSX B31001420180043

Applicant: Nantong Changrong electromechanical Co., Ltd
Registered address of applicant: Group 3, NanYang Village, Hai'an Development Zone, Jiangsu Province, China
Manufacturer: Nantong Changrong electromechanical Co., Ltd
Manufacturing address: Group 3, NanYang Village, Hai'an Development Zone, Jiangsu Province, China
Category of equipment: Lift major component
Type of equipment: Rope termination
Name of product: Rope termination
Model of product: D8
Type test report No.: T14-B310-18-043, T14-B310-22-027

After type test, it is confirmed that the product complies with the requirements of *TSG T7007—2016 Regulation for type tests of lifts*.

Applicable product model of the certificate: D8.

See appendix for applicable product parameters and configuration of the certificate.



NETEC Inspection and Testing (Beijing) Co., Ltd.
National Elevator Inspection and Testing Center

Note:

1. The applicant has responsibilities to ensure that the products conform to the requirements of the safety technical specifications and relative standards, and to ensure that the products are consistent with the tested sample mentioned above.
2. This certificate is not applicable to lift safety protection component and major component manufactured after the review date.

Appendix**Applicable Parameters Range and Configuration of
Rope Termination**

Construction	Self tightening wedge type sockets
Material grade of rope sleeve	Q235
Material grade of wedge	AlSi9Cu3
Material grade of bar	35#
Wedge angle	15°
Diameter of bar	≥10.6 mm
Diameter of rope	8mm
Minimum breaking load of applicable rope	≤46 kN
Applicable environment	Indoor

